

CITY OF WILLIAMSBURG, KENTUCKY
ORDINANCE NO. 19- 001

AN ORDINANCE OF THE CITY OF WILLIAMSBURG, KENTUCKY, REVISING THE POLLUTANT DISCHARGE LIMITS AND RESTRICTED DISCHARGES CONTAINED IN ORDINANCE NO. 12-004 "SEWER SYSTEM USE REGULATIONS."

WHEREAS, the City of Williamsburg, KY, has determined the need to revise the Sewer System Use Regulations based upon a local limits re-evaluation for Williamsburg's Pretreatment Program dated March 12, 2019;

NOW THEREFORE, BE IT ORDAINED by the City of Williamsburg, Kentucky, that Ordinance No. 12-0004 "Sewer System Use Regulations", dated May 16, 2012, is revised and amended as follows:

ARTICLE V. POLLUTANT DISCHARGE LIMITS


Section B. Restricted Discharges

11. The following limitations are established for characteristics of any wastewaters to be discharged into the municipal sewer system:

Parameter	Daily Maximum Allowable Concentration (milligrams per Liter)
Arsenic	0.28
Cadmium	0.05
Chromium, Total	2.50
Chromium, Hexavalent	2.43
Copper	1.00
Cyanide, Total	0.34
Lead	0.29
Mercury	0.002
Nickel	2.35
Selenium	0.65
Silver	0.31
Zinc	2.10

This Ordinance shall take effect after its' passage and upon publication.

CITY OF WILLIAMSBURG, KENTUCKY



BY: RODDY HARRISON, MAYOR

ATTEST:



Teresa Black, City Clerk

First Reading: June 17, 2019

Second Reading: June 19, 2019